



CERT

DIN-DVGW type examination certificate

DIN-DVGW-Baumusterprüfzertifikat

NW-7101DN0695

Registration Number
Registriernummer

Field of Application <i>Anwendungsbereich</i>	products of water supply <i>Produkte der Wasserversorgung</i>
Owner of Certificate <i>Zertifikatinhaber</i>	Toscelik Profil ve Sac Endüstrisi AS Türkmen Beldesi Büyüktüysüz Mah. Ali Ilbeyli Cad. No. 18, TR-80950 TOPRAKCALE / OSMANIYE
Distributor <i>Vertreiber</i>	Toscelik Profil ve Sac Endüstrisi AS Türkmen Beldesi Büyüktüysüz Mah. Ali Ilbeyli Cad. No. 18, TR-80950 TOPRAKCALE / OSMANIYE
Product Category <i>Produktart</i>	Steel pipes: galvanized medium-weight screwed pipe, welded (7101)
Product description <i>Produktbezeichnung</i>	galvanized medium-weight screwed pipe, welded, for drinking water installation
Model <i>Modell</i>	Toscelik
Test reports <i>Prüfberichte</i>	Type testing: 600 134 631 from 18.12.2022 (TSZ)
Test basis <i>Prüfgrundlagen</i>	DIN EN 10255 (01.07.2007) DIN EN 10240 (01.02.1998) UBA BWGL-Metalle (11.01.2023)

Date of Expiry / File No. 18.12.2027 / 18-0567-WNE
Ablaufdatum / Aktenzeichen

28.04.2023 GI A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

G. Schmidt



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-01

DVGW CERT GmbH
Zertifizierungsstelle

Josef-Wirmer-Str. 1-3
53123 Bonn

Tel. +49 228 91 88 - 888
Fax +49 228 91 88 - 993

www.dvgw-cert.com
info@dvgw-cert.com

Type	Technical Data	Remarks
<i>Typ</i>	<i>Technische Daten</i>	<i>Bemerkungen</i>
Toscelik	Nominal diameter: 21,3 - 165,1 mm	thread sizes: 1/2" - 6"

Type Variation	Explanations
<i>Ausführungsvariante</i>	<i>Erläuterungen</i>
Toscelik	Pipe ends with conical external thread according to EN 10226-1
Toscelik	Pipe ends without thread



DVGW certificate of conformity hygiene

DVGW-Konformitätsbestätigung Hygiene

HW-1001DQ0603
Registration Number
Registriernummer

Confirmation of Conformity <i>Konformitätsbestätigung</i>	system 1+ with audit testing <i>System 1+ mit Fremdüberwachung</i>
Owner of certificate <i>Zertifikatinhaber</i>	Toscelik Profil ve Sac Endüstrisi AS Türkmen Beldesi Büyüktüysüz Mah. Ali Ilbeyli Cad. No. 18, TR-80950 TOPRAKCALE / OSMANIYE
Manufacturer <i>Hersteller</i>	Toscelik Profil ve Sac Endüstrisi AS Türkmen Beldesi Büyüktüysüz Mah. Ali Ilbeyli Cad. No. 18, TR-80950 TOPRAKCALE / OSMANIYE
Product Category <i>Produktart</i>	Hygienic suitability according to system 1+: Metal components, product group A/B (1001)
Product description <i>Produktbezeichnung</i>	Galvanised steel pipe for drinking water installations
Material/Model <i>Werkstoff/Modell</i>	Toscelik Carbon Steel Pipe/ S195T
Test reports <i>Prüfberichte</i>	Certification report: dated 15.10.2025 (ZGW) Report of initial inspection: 62103-1116945-24-0998-W dated 09.04.2025 (TTR)
Test basis <i>Prüfgrundlagen</i>	DVGW CERT ZP 1000 (03.09.2024) UBA BWGL-Metalle (21.08.2025)
Date of Expiry / File No. <i>Ablaufdatum / Aktenzeichen</i>	15.10.2030 / 24-0998-WHE

This is to confirm that, based on the DVGW CERT ZP 1000 certification programme, the product information made available, including the recipe specifications and the above-mentioned assessment report, the above-mentioned product/component meets the requirements of, and complies with, the assessment basis/guideline of the German Federal Environmental Agency mentioned under Test Specifications for the temperature range listed on the reverse.

15.10.2025 Pek A-1/2

Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

J. A. W. Zi



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvw-cert.com
www.dvzw-cert.com

Type <i>Typ</i>	Technical Data <i>Technische Daten</i>	Remarks <i>Bemerkungen</i>
Pipe S195T	Application: drinking water installation Weighing factor a: 1 Production method: hot-dip galvanizing	

The assessment reports listed under Test Reports are an integral part of the confirmation of conformity. The confirmation of conformity is valid from date of issue and remains valid as long as the requirements listed under "Notes" are met.

Notes

The confirmation of conformity was issued on the condition that the raw materials used to manufacture the product or rather their composition and/or components, including the latter's manufacturer and supplier chain have been disclosed in full and no other substances are contained in the product. The validity of this document expires in the event of modifications to the composition of the product or to the processing conditions that were not coordinated with the certification body and in the event of non-compliance with the conformity requirements as well as in the event of termination of the 1+ system monitoring programme of certification body and manufacturer.

The results of our tests and the assessments apply to the test items examined and the statutory regulations valid at the time of testing. Without our express written approval, this document may only be published or reproduced in complete and unaltered form.

This confirmation of conformity is only valid in conjunction with a corresponding entry in the Internet directory of DVGW CERT GmbH (<http://www.dvgw-cert.com>). The confirmation of conformity remains the property of DVGW CERT GmbH and must be returned to DVGW CERT GmbH upon request.

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Hot-dip galvanised steel can only be used for cold water installations.



DVGW certificate of conformity hygiene

DVGW-Konformitätsbestätigung Hygiene

HW-1001DQ0604
Registration Number
Registriernummer

Confirmation of Conformity system 1+ with audit testing
Konformitätsbestätigung System 1+ mit Fremdüberwachung

Owner of certificate Toscelik Profil ve Sac Endüstrisi AS
Zertifikatinhaber Türkmen Beldesi Büyüktüysüz Mah. Ali Ilbeyli Cad. No. 18, TR-80950
TOPRAKCALE / OSMANIYE

Manufacturer Toscelik Profil ve Sac Endüstrisi AS
Hersteller Türkmen Beldesi Büyüktüysüz Mah. Ali Ilbeyli Cad. No. 18, TR-80950
TOPRAKCALE / OSMANIYE

Product Category Hygienic suitability according to system 1+: Metal components, product
Produktart group A/B (1001)

Product description Galvanised steel pipe for drinking water installations
Produktbezeichnung

Material/Model Toscelik Carbon Steel Pipe/ S235JR
Werkstoff/Modell

Test reports Certification report: dated 15.10.2025 (ZGW)
Prüfberichte Report of initial inspection: 62103-1116945-24-0998-W dated 09.04.2025
(TTR)

Test basis DVGW CERT ZP 1000 (03.09.2024)
Prüfgrundlagen UBA BWGL-Metalle (21.08.2025)

Date of Expiry / File No. 15.10.2030 / 24-0998-WHE
Ablaufdatum / Aktenzeichen

This is to confirm that, based on the DVGW CERT ZP 1000 certification programme, the product information made available, including the recipe specifications and the above-mentioned assessment report, the above-mentioned product/component meets the requirements of, and complies with, the assessment basis/guideline of the German Federal Environmental Agency mentioned under Test Specifications for the temperature range listed on the reverse.

70028-04-A-DE

15.10.2025 Pek A-1/2
Date, Issued by, Sheet, Head of Certification Body
Datum, Bearbeiter, Blatt, Leiter der Zertifizierungsstelle

A. W. Z.



Deutsche
Akkreditierungsstelle
D-ZE-16028-01-00

DVGW CERT GmbH
Josef-Wirmer-Str. 1-3
53123 Bonn
Tel. +49 228 9188-888
info@dvwg-cert.com
www.dvbw-cert.com

Type Typ	Technical Data Technische Daten	Remarks Bemerkungen
Pipe S235JR	Application: drinking water installation Weighing factor a: 1 Production method: hot-dip galvanizing	

The assessment reports listed under Test Reports are an integral part of the confirmation of conformity. The confirmation of conformity is valid from date of issue and remains valid as long as the requirements listed under "Notes" are met.

Notes

The confirmation of conformity was issued on the condition that the raw materials used to manufacture the product or rather their composition and/or components, including the latter's manufacturer and supplier chain have been disclosed in full and no other substances are contained in the product. The validity of this document expires in the event of modifications to the composition of the product or to the processing conditions that were not coordinated with the certification body and in the event of non-compliance with the conformity requirements as well as in the event of termination of the 1+ system monitoring programme of certification body and manufacturer.

The results of our tests and the assessments apply to the test items examined and the statutory regulations valid at the time of testing. Without our express written approval, this document may only be published or reproduced in complete and unaltered form.

This confirmation of conformity is only valid in conjunction with a corresponding entry in the Internet directory of DVGW CERT GmbH (<http://www.dvgw-cert.com>). The confirmation of conformity remains the property of DVGW CERT GmbH and must be returned to DVGW CERT GmbH upon request.

Hints of Utilization / Remarks

Verwendungshinweise / Bemerkungen

Hot-dip galvanised steel can only be used for cold water installations.