

CERTIFICATE OF COMPLIANCE

Certificate Number 20161006-EX26893
Report Reference EX26893-20151117
Issue Date 2016-OCTOBER-06

Issued to: Toscelik Profil ve Sac End. A.S
Organize Sanayi Bolgesi
80950 Toprakkale Osmaniye TURKEY

**This is to certify that
representative samples of**

METALLIC SPRINKLER PIPE
See Addendum Page for Models


Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 852, Metallic Sprinkler Pipe for Fire Protection Service.
ULC/ORD C199S, Light Wall Steel Pipes for Sprinkler
Systems for Fire Protection Service.

Additional Information: See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



CERTIFICATE OF COMPLIANCE

Certificate Number 20161006-EX26893
Report Reference EX26893-20151117
Issue Date 2016-OCTOBER-06

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Metallic Sprinkler Pipe.


Schedule 30, 40, 80, and Weight Class STD steel sprinkler pipe for wet, dry, preaction and deluge type sprinkler systems with unthreaded ends intended to be joined by welding or Listed Rubber Gasketed Fittings when installed in accordance with the fitting manufacturer's specifications.

Schedule 30 steel pipe in the 8 and 12 inch sizes.

Schedule 40 steel pipe in the 4, 6, 8, and 10 inch sizes.

Schedule 80 steel pipe in the 3 and 8 inch sizes.

Weight Class STD steel pipe in the 12 inch sizes.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

