



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Product	Listing Country	Nominal Pipe Size, in.	Rated Working Pressure, psi	Rated Working Pressure, kPa	Certification Type
Schedule 40 ^{b, e, g, j, m, n, p}	Turkey	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1205	FM Approved
Schedule 40 ^{b, e, j, m, n, p}	Turkey	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4	300	2070	FM Approved

Notes: b - FM Approved for use with FM Approved pipe fittings when threaded.
e - Any FM Approved pipe coupling or fitting suitable for use with Schedule 10 pipe may be used with this product at the lower rated pressure of the pipe or the fitting.
g - FM Approved for use with plain-end fittings.
j - ½ in (15 mm) and 3/5 in (20 mm) nominal size limited for use in valve trim.
m - FM Approved for use in all steel sprinkler systems composed of uncoated steel pipe.
n - FM Approved for use in hybrid sprinkler systems composed of uncoated steel and plastic piping.
p - Manufactured out of ASTM A53 Grade A and B steel.

Prepared for: Tosçelik Profil ve Sac Endüstrisi A.Ş., Organize Sanayi Bölgesi
Toprakkale, Osmaniye 80950, Turkey

Manufacturing Location: Tosçelik Profil ve Sac Endüstrisi A.Ş., Organize Sanayi Bölgesi
Toprakkale, Osmaniye 80950, Turkey

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3056312

Approval Granted: November 10, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read "D.B. Fuller".

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group



Certificate of Compliance

This certificate is issued for the following:

Steel Pipe for Automatic Fire Sprinkler Systems

Product	Listing Country	Nominal Pipe Size, in.	Rated Working Pressure, psi	Rated Working Pressure, kPa	Certification Type
Schedule 80 ^{b, e, g, j, m, n, p}	Turkey	1/2, 3/4, 1, 1-1/4, 1-1/2, 2	175	1205	FM Approved
Schedule 80 ^{b, e, j, m, n, p}	Turkey	1/2, 3/4, 1, 1-1/4, 1-1/2, 2, 2-1/2, 3, 3-1/2, 4	300	2070	FM Approved

Notes: b - FM Approved for use with FM Approved pipe fittings when threaded.
e - Any FM Approved pipe coupling or fitting suitable for use with Schedule 10 pipe may be used with this product at the lower rated pressure of the pipe or the fitting.
g - FM Approved for use with plain-end fittings.
j - ½ in (15 mm) and 3/5 in (20 mm) nominal size limited for use in valve trim.
m - FM Approved for use in all steel sprinkler systems composed of uncoated steel pipe.
n - FM Approved for use in hybrid sprinkler systems composed of uncoated steel and plastic piping.
p - Manufactured out of ASTM A53 Grade A and B steel.

Prepared for: Tosçelik Profil ve Sac Endüstrisi A.Ş., Organize Sanayi Bölgesi
Toprakkale, Osmaniye 80950, Turkey

Manufacturing Location: Tosçelik Profil ve Sac Endüstrisi A.Ş., Organize Sanayi Bölgesi
Toprakkale, Osmaniye 80950, Turkey

FM Approvals Class: 1630 – “Steel Pipe for Automatic Fire Sprinkler Systems”

Approval Identification: 3056312

Approval Granted: November 10, 2017

To verify the availability of the Approved product, please refer to www.approvalguide.com

Said Approval is subject to satisfactory field performance, continuing Surveillance Audits, and strict conformity to the constructions as shown in the Approval Guide, an online resource of FM Approvals.

A handwritten signature in black ink, appearing to read 'D.B. Fuller', written over a horizontal line.

David B. Fuller
VP, Manager – Fire Protection
FM Approvals
1151 Boston-Providence Turnpike
Norwood, MA 02062 USA



Member of the FM Global Group